



NOTES:

1. For all depths of cover less than two (2) feet, pipe must be schedule 40 PVC. For depths of cover greater than two (2) feet, flexible pipe may be used.
2. A watertight connection shall be maintained at all transitions from schedule 40 PVC to any other pipe type.

NTS

Date: 6-3-2013