

3.2.5 STUDY FACILITIES

3.2.5.1 General

This space use category includes study rooms, stacks, open-stack reading rooms, and library processing spaces.

3.2.5.2 Facility Planning and Design

RESERVED

3.2.5.3 Windows and Walls

RESERVED

3.2.5.4 Doors

RESERVED

3.2.5.5 Accessibility

RESERVED

3.2.5.6 Furniture and Equipment

RESERVED

3.2.5.7 Materials and Finishes

RESERVED

3.2.5.8 Building Systems

3.2.5.8.1 General

RESERVED

3.2.5.8.2 Plumbing

- Refer to Section 3.3.3 – Plumbing Systems.

3.2.5.8.3 Heating, Ventilating and Air Conditioning

- Refer to Section 3.3.1 – HVAC Systems.

3.2.5.8.4 Electrical

- Refer to Section 3.3.2 – Electrical Design Criteria.
- Lighting in study and library processing spaces shall consist of 2x4 recessed parabolic fixtures with 2-T5 lamps controlled with local wall switches.
- Lighting in stacks and open-stack reading rooms shall be 1x4 recessed with 2-T5 lamps controlled by multiple local switches at room/entrance.
- 20A - 125A electrical duplex outlets shall be provide in study and open-stack reading rooms for portable laptop use by students at each desk location.

- Emergency lighting and exit lighting must be provide in large study and open-stack reading rooms to meet local fire codes.
- See Section 3.3.2 for recommended illumination levels.

3.2.5.8.5 Communications

- Tele/data wall or floor outlets shall be provided at each student desk in study and open-stack reading rooms.

3.2.5.9 Acoustics

RESERVED

3.2.5.10 Security

RESERVED