

## Division 10 - Specialties

### 10 11 00 Visual Display Boards

1. Specify chalkboards only when specifically requested by the University.  
Product: Vitrasite, standard black with clear anodized aluminum trim, chalk rails and track for map hooks. Provide sliding boards where space allows.
2. Typically specify dry marker boards in classrooms and conference rooms.
3. Specify tack boards in conjunction with chalk boards and marker boards.

### 10 14 00 Signage

1. Refer to the George Mason University Environmental Graphics Standards (TBP).
2. Provide an interior signage schedule to George Mason University for review.
3. Signage Manufacturer: New Hermes, all components: Frame: 6 x 6 inches #743-536; Braille Panel: Gray #271-226 2.220 inches x 5.930 inches; Braille: Routed 1/2-inch tall strip, Dots: 0.239-inch tall; White Gravotac Numerals 0.8-inch tall, 1/32-inch thick, Helvetica Medium; Name Panel: Red # 248-226 3.711 inches x 5.930 inches Name: 0.4-inch tall.

### 10 21 13 Toilet Partitions

1. Specify toilet partitions as ceiling hung or wall hung. Provide adequate structure to support partitions without sagging or warping. Specify vandal-resistant attachments.

### 10 26 00 Wall Protection

1. Provide stainless steel corner protection in kitchens and in back-of-house areas where carts will be used.

### 10 28 00 Toilet and Bath Accessories

1. Sanitary Dispensing Vendors: Rochester Midland Model J2 White Enamel Metal 14 3/4-inches w 6 1/2-inches d x 20-inches h, or approved equal.
2. Provide baby changing stations in Men's and Women's toilet rooms on the entry level of most buildings.
3. Electric Hand Dryers: N/A.
4. The following toilet and bath accessories will be provided by George Mason University, and are to be specified to be installed by the Contractor.

Toilet Tissue Dispensers.

Roll-Towel Dispensers.

Soap Dispensers.

### 10 44 00 Fire Protection Specialties

1. Specify solid cabinet doors with a small window made of polycarbonate or other plastic glazing to verify the presence of fire extinguisher. Specify cabinet sizes to accommodate the extinguisher sizes specified. Break-glass faced fire extinguisher cabinets are not permitted.

2. Specify 5 pound ABC type extinguishers allowing for 75 feet travel distance for Class A light hazards.
3. Bottom of cabinet shall be mounted a minimum of 16" and no higher than 48" above floor.
4. Fire extinguishers cabinets shall be incorporated into all projects as required by code.
5. Fire extinguishers shall be incorporated into all projects as required by code.